



Steam Cycle HTGR

Farshid Shahrokhi

February 2, 2022

Panel Discussions


**NASE&M Committee on Laying the Foundation
for New and Advanced Nuclear Reactors in the
United States**




Framatome HTGR Design Experience

Developing a Gen IV Future

- **1960s, 70s, and 80s**
 - Framatome **GmbH** – Pebble Bed HTGRs
 - AVR – 46 MWth test reactor, THTR – 750 MWth cogeneration reactor, HTR-Module – 200 MWth
- **1990s and early 2000s**
 - GT-MHR – 600 MWth prismatic core, Brayton cycle. Collaboration with Russian Federation and General Atomics
- **Mid to late 2000s**
 - **ANTARES** Project - 600 MWth prismatic core, Indirect cycle with heat recovery steam generator
 - **US DOE NGNP** project - Modified ANTARES design
- **Late 2000s to present** (North America)
 - **Steam Cycle HTGR** – 4x625 MWth, prismatic core **cogeneration** of process steam and electricity
 - **Four scaled variances** of the reference plant (All use the same fuel and the same fuel block.)
 - **315 MWth** single SG
 - **180 MWth** EU steam only
 - **54 MWth** remote site
 - **7 MWth** mobile





Steam Cycle HTGR (SC-HTGR)

Framatome Inc. Reference HTGR

- Designed to serve industrial energy market

Power and process heat/steam

- Key Features

Scalable design from 4-module 2500-MWth plant to single-module 7-MWth micro mobile plant

Flexible operation for load following/load switching

Passive decay heat removal

Inherent and walk-away safety

TRISO coated particle fuel

High technology readiness levels



Conventional steam cycle

No new material or basic R&D needs

- Design Status – Conceptual

- Deployment Schedule – ≤10 years (final design, license, construct)

4 x 625 MWth SC-HTGR



Reactor outlet temperature	750°C
Reactor inlet temperature	325°C
Primary coolant pressure	6 MPa
Main circulator power	4 MWe (each)
Main steam temperature	566°C
Main steam pressure	16.7 MPa

Very strong safety case for HTGR

- ✓ Intrinsic safety, fuel robustness
- ✓ Resistance to natural disasters, human error/equipment failure
- ✓ Following DBAs:
 - ✓ No explosive gases produced
 - ✓ No need for evacuation
 - ✓ Repair and return to power operation

SC-HTGR Used Fuel Path


SC-HTGR Fuel

- UCO Kernel, TRISO coated particles, Enrichment 14.5% ^{235}U ,
- Graphite fuel blocks – 1020 blocks
- Refueling Interval – 18 to 24 months, $\frac{1}{2}$ core replacement
- Refueling time – 21 days breaker to breaker
- Fuel Qualification
 - Step 1 – Generic [Topical Report EPRI-AR-1(NP), SER expected June 2020]
 - Step 2 – Design specific – DOE AGR irradiation data and design specific accident scenarios
- Burnup – qualified up to 19% FIMA, also exploring deep-burn option (60%FIMA)
- Used fuel disposition path-
 - Once through – fuel block or fuel compact long term retrievable or permanent storage
 - Reprocessing



HTGR Single Reactor Module Design

Versatile Solution for Many Applications



framatome

